

Declaration of conformity

according to

Low Voltage Directive 2014/35/EU and EMC Directive 2014/30/EU

Type of equipment

Control Panel for Fire alarm system

Model name

EKO-KE2, EKO-KE4

Manufacturer's name, address, telephone and fax no

EKOVENT AB

Mejselgatan 7

SE-235 32 Vellinge, Sweden

Tel +46 40 421600

Fax +46 40 422518

The following standards and/or technical specifications, which comply with good engineering practice in safety matters in force within the EEA, have been applied:

Test report

Ref.No. 11061 and 0308-004-00 issued by Dectron AB

Ref.No. 10168 issued by Dectron AB

*Standards**Low Voltage Directive: SS-EN 61010-1:2001, -C1:2002*

EMC Emission: EN 61000-6-3:2007

EMC Immunity: EN 50130-4:1995, -A1:1998, -A2:2003, EN 61000-4-2, -3, -4, -5, -6, -11

We declare under our sole responsibility that the equipment follows the provisions of the Directives stated above.

Vellinge 2017-04-25



Michael Brändström
R&D Manager